Annex to Solar Keymark Certificate

Licence Number	SKM 10132.2
Date issued	2024-09-20
Issued by	DQS Hellas

Licence holder	PAPAEMMANOUEL S.A.	Country	Greece
Brand (optional)	SOLAR FLAME MSFC100-300	Web	www.papaemmanouel.gr
Street, Number	Thesi Loumaria	E-mail	exports@papaemmanouel.gr
Postcode, City	32009 Oinofyta Viotias	Tel	+30 22620 31931

Collector Type	Flat plate collector

Collector name	Gross area (A_G)	Gross length	Gross width	Gross height	Power output per collector Gb = 850 W/m2, Gd = 150 W/m2 & u = 1.3 m/s $\vartheta_m - \vartheta_a$					
					0 K	10 K	30 K	50 K	70 K	90 K
	m²	mm	mm	mm	W	W	W	W	W	W
MSFC100-300	3.02	2,160	1,400	86	2,445	2,331	2,088	1,825	1,541	1,237
					0	0	0	0	0	0
Power output per m² gross area					810	772	692	604	510	409

Performance parameters test method	Steady state - outdoor									
Performance parameters (related to A_G)	η0, b	a1	a2	a3	a4	a5	a6	a7	a8	Kd
Units	-	W/(m²K)	W/(m²K²)	J/(m³K)	-	J/(m²K)	s/m	W/(m²K⁴)	W/(m²K⁴)	-
Test results	0.820	3.68	0.008	0.000	0.00	9,348	0.000	0.00	0.0E+00	0.91

Incidence angle modifier test method		Steady state - outdoor								
Incidence angle modifier	Angle	10°	20°	30°	40°	50°	60°	70°	80°	90°
Transversal	$K_{\theta T,coll}$	1.00	1.00	0.99	0.98	0.95	0.89	0.76	0.50	0.00
Longitudinal	$K_{\theta L,coll}$	1.00	1.00	0.99	0.98	0.95	0.89	0.76	0.50	0.00

Heat transfer medium for testing	Water		
Flow rate for testing (per gross area, A_G)	dm/dt	0.020	kg/(sm²)
Maximum temperature difference during thermal performance test	$(\vartheta_m-\vartheta_a)_{max}$	60	K
Standard stagnation temperature (G = 1000 W/m²; ϑ_a = 30 °C)	ϑ_{stg}	231	°C
Maximum operating temperature	ϑ_{max_op}	250	°C
Maximum operating pressure	$p_{max,op}$		kPa

Testing laboratory	NCSR Demokritos / Solar & other Energy System	www.solar.demokritos.gr	
Test report(s)	4418 DE1 4420 DQ1	Dated	18/07/24 13/09/24

Comments of testing laboratory

Ver. 6.2 (13.01.2022)

N.C.S.R. "DEMOKRITOS"
SOLAR ENERGY LABORATORY
Tel: +210 6503815 - Fax: +210 6544592
P.O. BOX 60037, 15310 Ag. Paraskevi, Greece

Annex to Solar Keymark Certificate	Licence Number	SKM 10132.2
Supplementary Information	Issued	2024-09-20

Gross Thermal Yield in kWh/collector at mean fluid temperature ϑ_m

Standard Locations		Athens			Davos			Stockholm			Würzburg		
Collector name	ϑ_m	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C
MSFC100-300		3,937	2,883	1,988	3,032	2,175	1,467	2,221	1,504	972	2,413	1,627	1,034
Gross Thermal Yield per m² gross		1,304	955	658	1,004	720	486	735	498	322	799	539	342
Annual efficiency, η_a		74%	54%	37%	62%	44%	30%	63%	43%	28%	64%	43%	28%
Fixed or tracking collector		Fixed (slope = latitude - 15°; rounded to nearest 5°)											
Annual irradiation on collector plane		1765 kWh/m²			1630 kWh/m²			1166 kWh/m²			1244 kWh/m²		
Mean annual ambient air		18.5°C			3.2°C			7.5°C			9.0°C		
Collector orientation or tracking		South, 25°			South, 30°			South, 45°			South, 35°		

The collector is operated at constant temperature ϑm (mean of in- and outlet temperatures). The calculation of the annual collector performance is performed with the official Solar Keymark spreadsheet tool Scenocalc Ver. 6.2 (13.01.2022). A detailed description of the calculations is available at http://www.estif.org/solarkeymarknew/

Additional Information

Collector heat transfer medium	Water-Glycole
The collector is deemed to be suitable for roof integration	No

The collector was tested successfully under the following conditions:

Climate class (A+, A, B or C)				A	--
G (W/m²) >	1000	ϑ_a (°C) >	20	H_x (MJ/m²) >	600
Maximum tested positive load				3000	Pa
Maximum tested negative load				3000	Pa
Hail resistance using steel ball (maximum drop height)				2	m

Additional collector attribute(s)

Using external power source(s) for normal	No	Active or passive measure(s) for self-protection	No
Co-generating thermal and electrical power	No	Façade collector(s)	No

Energy Labelling Information

	Reference Area, A_{sol} (m²)
MSFC100-300	3.02

Additional Informative Technical Data

Hydraulic Designation Code	Aperture Area, A_a (m²)
1-H-1234S-A:7.2,39040-C:20.6, 1470-D	2.88

Data required for CDR (EU) No 811/2013 - Reference Area

Collector efficiency (η_{col})	65%

Remark: Collector efficiency (ηcol) is defined in CDR (EU) No 811/2013 as collector efficiency of the solar collector at a temperature difference between the solar collector and the surrounding air of 40 K and a global solar irradiance of 1000 W/m², expressed in % and rounded to the nearest integer. Deviating from the regulation ηcol is based on reference area (Asol) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806:2017.

Data required for CDR (EU) No 812/2013 - Reference Area A_{sol}

Zero-loss efficiency (η_0)	0.81	--
First-order coefficient (a_1)	3.68	W/(m²K)
Second-order coefficient (a_2)	0.008	W/(m²K²)
Incidence angle modifier IAM (50°)	0.96	--

Remark: The data given in this section are related to collector reference area (A_{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806. Consistent data sets for either aperture or gross area can be used in calculations like in the regulation 811 and 812 and simulation programs.