

Annex to Solar Keymark Certificate					Licence Number		011-7S3274 F							
					Date issued		2024-12-02							
					Issued by		DIN CERTCO							
Licence holder		INTERDOMO GmbH			Country		Germany							
Brand (optional)					Web		http://www.interdomo.de							
Street, Number		Rheiner Straße 151			E-mail		kontakt@interdomo.de							
Postcode, City		D- 48282 Emsdetten			Tel		+49 2572 23-0							
Collector Type					Flat plate collector									
Collector name					Power output per collector									
					$G_b = 850 \text{ W/m}^2, G_d = 150 \text{ W/m}^2 \text{ \& } u = 1.3 \text{ m/s}$									
					$\vartheta_m - \vartheta_a$									
					0 K	10 K	30 K	50 K	70 K	85 K				
					m ²	mm	mm	mm	mm	mm				
DomoSun SMI					2.32	2 037	1 137	80	1 770	1 687	1 501	1 290	1 052	857
Power output per m² gross area					764	728	648	557	454	370				
Performance parameters test method		Steady state - indoor												
Performance parameters (related to A_G)		η_0, b	a1	a2	a3	a4	a5	a6	a7	a8	Kd			
Units		-	W/(m ² K)	W/(m ² K ²)	J/(m ³ K)	-	J/(m ² K)	s/m	W/(m ² K ⁴)	W/(m ² K ⁴)	-			
Test results		0.776	3.45	0.014			5 556				0.90			
Incidence angle modifier test method		Quasi dynamic - outdoor												
Incidence angle modifier		Angle	10°	20°	30°	40°	50°	60°	70°	80°	90°			
Transversal		$K_{\theta T, coll}$	1.00	0.99	0.98	0.97	0.94	0.89	0.78	0.46	0.00			
Longitudinal		$K_{\theta L, coll}$	1.00	0.99	0.98	0.97	0.94	0.87	0.78	0.46	0.00			
Heat transfer medium for testing					Water									
Flow rate for testing (per gross area, A_G)					dm/dt		0.036		kg/(sm²)					
Maximum temperature difference during thermal performance test					$(\vartheta_m - \vartheta_a)_{max}$		55		K					
Standard stagnation temperature (G = 1000 W/m²; $\vartheta_a = 30 \text{ }^\circ\text{C}$)					ϑ_{stg}		210		°C					
Maximum operating temperature					$\vartheta_{max, op}$		110		°C					
Maximum operating pressure					$p_{max, op}$		1000		kPa					
Testing laboratory		ISFH CalTeC			https://isfh.de/									
Test report(s)		172-24/B			Dated		02.12.2024							
Comments of testing laboratory					Ver. 6.2 (13.01.2022)									
					Institut für Solarenergieforschung GmbH Am Ohrberg 1 D-31880 Emmerthal Tel.: 05151/999-100 Fax: 05151/999-500									
DIN CERTCO • Alboinstraße 56 • 12103 Berlin, Germany Tel: +49 30 7562-1131 • Fax: +49 30 7562-1141 • E-Mail: info@dincertco.de • www.dincertco.de														

Annex to Solar Keymark Certificate		Licence Number												
Supplementary Information		011-7S3274 F												
		Issued												
		2024-12-02												
Gross Thermal Yield in kWh/collector at mean fluid temperature ϑ_m														
	Standard Locations	Athens			Davos			Stockholm			Würzburg			
Collector name	ϑ_m	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	
DomoSun SMI		2 818	2 027	1 330	2 153	1 496	941	1 583	1 043	632	1 721	1 127	672	
Gross Thermal Yield per m ² gross area		1 217	875	574	929	646	406	684	450	273	743	487	290	
Annual efficiency, η_a		69%	50%	33%	57%	40%	25%	59%	39%	23%	60%	39%	23%	
Fixed or tracking collector		Fixed (slope = latitude - 15°; rounded to nearest 5°)												
Annual irradiation on collector plane		1765 kWh/m ²			1630 kWh/m ²			1166 kWh/m ²			1244 kWh/m ²			
Mean annual ambient air temperature		18.5°C			3.2°C			7.5°C			9.0°C			
Collector orientation or tracking mode		South, 25°			South, 30°			South, 45°			South, 35°			
The collector is operated at constant temperature ϑ_m (mean of in- and outlet temperatures). The calculation of the annual collector performance is performed with the official Solar Keymark spreadsheet tool Scenocalc Ver. 6.2 (13.01.2022). A detailed description of the calculations is available at http://www.estif.org/solarkeymarknew/														
Additional Information														
Collector heat transfer medium											Water-Glycole			
The collector is deemed to be suitable for roof integration											No			
The collector was tested successfully under the following conditions:														
Climate class (A+, A, B or C)											B		--	
G (W/m ²) >		900		ϑ_a (°C) >		15		H _x (MJ/m ²) >		540				
Maximum tested positive load											3000		Pa	
Maximum tested negative load											2000		Pa	
Hail resistance using steel ball (maximum drop height)											2		m	
Additional collector attribute(s)														
Using external power source(s) for normal operation											No		Active or passive measure(s) for self-protection	No
Co-generating thermal and electrical power											No		Façade collector(s)	No
Energy Labelling Information							Additional Informative Technical Data							
	Reference Area, A _{sol} (m ²)						Hydraulic Designation Code				Aperture Area, A _a (m ²)			
DomoSun SMI	2.32						2-VH-12S-A:11.3,8500-C:16,100				2.13			
Data required for CDR (EU) No 811/2013 - Reference Area A_{sol}							Data required for CDR (EU) No 812/2013 - Reference Area A_{sol}							
Collector efficiency (η_{col})							60%							
Remark: Collector efficiency (η_{col}) is defined in CDR (EU) No 811/2013 as collector efficiency of the solar collector at a temperature difference between the solar collector and the surrounding air of 40 K and a global solar irradiance of 1000 W/m ² , expressed in % and rounded to the nearest integer. Deviating from the regulation η_{col} is based on reference area (A _{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806:2017.							Zero-loss efficiency (η_0)				0.76			--
							First-order coefficient (a ₁)				3.45			W/(m ² K)
							Second-order coefficient (a ₂)				0.014			W/(m ² K ²)
							Incidence angle modifier IAM (50°)				0.93			--
Remark: The data given in this section are related to collector reference area (A _{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806. Consistent data sets for either aperture or gross area can be used in calculations like in the regulation 811 and 812 and simulation programs.														
DIN CERTCO • Alboinstraße 56 • 12103 Berlin, Germany														
Tel: +49 30 7562-1131 • Fax: +49 30 7562-1141 • E-Mail: info@dincertco.de • www.dincertco.de														